

Odniesienie

LAMILUX CI-System Lichtband B



Projekt - Schneider Electric

Essential Info

Place / country:	Regensburg, Germany
Year:	2011
Building type:	Production shed
Solutions:	CI System Continuous Rooflight B Adapter frames Hollow polycarbonate sections CI System Smoke Lift B Electric motorised opener Wind and rain sensors
Efficiency:	44% energy saving Uw=1,7 W/(m²K) vs. Uw=3,1 W/(m²K) as per German Energy Performance of Buildings Directive 2009

Complete production plant rehabilitation due to very poor Uw values. All work was carried out while production continued as normal.

- Continuous rooflights designed and installed with a Uw value of 1.7 W/(m²K) as per EN ISO 10077-1
- Adapter frames to hold the new continuous continuous rooflight systems on the existing supporting structure
- Multi-layer glazing in an opal, glare-reducing design; U-value = 1.6 W/(m²K), 37% light transmission and 39% total energy transmission
- Double flap systems with CO2 remote and thermal release for SHEV function
- Wind and rain sensors with optical display
- CO2 alarm stations
- SPC control for ventilation function

LAMILUX HEINRICH STRUNZ GMBH

Zehstraße 2 - P.O. Box 1540 - 95105 Rehau/Niemcy - Telefon: +49/(0)92 83/5 95-0 - Faks: +49/(0)92 83/5 95-29 0
E-mail: information@lamilux.de - www.lamilux.de

Odniesienie

LAMILUX CI-System Lichtband B



Projekt - Schneider Electric



LAMILUX HEINRICH STRUNZ GMBH

Zehstraße 2 - P.O. Box 1540 - 95105 Rehau/Niemcy - Telefon: +49/(0)92 83/5 95-0 - Faks: +49/(0)92 83/5 95-29 0

E-mail: information@lamilux.de - www.lamilux.de